

DRI Hearing – March 1, 2011

Orleans Comprehensive Wastewater Management Plan
Final/Single Environmental Impact Report



Orleans CWMP

Overview

1. Recap project highlights
2. Describe Recommended Plan
3. Review MEPA results
4. Address public comments from January 18, 2011 public hearing
5. Provide further public input to Cape Cod Commission's DRI process

2 Orleans CWMP

CWMP Phases

1. Needs Assessment
2. Develop/Screen Alternatives
3. Detailed Evaluation of Alternatives
4. Develop Recommended Plan
 - Draft CWMP (Filed with EENF)
 - Final CWMP (Part of S/FEIR)
5. MEPA and DRI review

3 Orleans CWMP

Chronology of CWMP Development

Needs Assessment — PM: Feb 2006
 Develop/Screen Alternatives — PM: Jan 2007
 Detailed Evaluation of Alternatives
 Public Meeting: May 2008
 Workshops: Jul & Aug 2008
 Develop Recommended Plan
 Public Meeting: Oct 2, 2008
 STM: Oct 27, 2008
 Publication of Final CWMP — Dec 2010

4 Orleans CWMP

Public Consultation Effort

Wastewater Management Steering Comm. — representatives of 6 boards

- Twice weekly meetings—2005 to 2009
- Over 500 hours of open meetings
- Compilation of consultant letters in Town office
- Weekly neighborhood workshops—2008

Citizens Advisory Comm.—adjunct to WMSC Board of Selectmen

- Representative on WMSC
- Periodic presentations by WMSC

MEPA and DRI reviews


5 Orleans CWMP

Chronology of Environmental Review

MEPA Expanded Environmental Notification Form (EENF) and draft CWMP
Environmental Monitor: May 6, 2009
 Extended review period: May 6 to Jun 30, 2009
 MEPA/DRI hearing: Jul 10, 2009
 EOEEA Sec'y decision: Jul 18, 2009

MEPA Single/Final Environmental Impact Report (S/FEIR) and Final CWMP
 Response to Comments: Dec 15, 2010
Environmental Monitor: Dec 22, 2010
 Review period: Dec 22, 2010 to Jan 21, 2011
 MEPA/DRI hearing: Jan 18, 2011
 EOEEA Sec'y decision: Jan 28, 2011

6 Orleans CWMP




Summary of Needs Assessment

Reducing nitrogen load to embayments is the principal problem
(2,800 lots—52% of all parcels)

Other needs can be largely addressed by strategic sewerage plans

- Sanitary needs
- Pond protection
- Water supply protection
- Affordable housing

7 Orleans CWMP



Composite Plan Evaluation

9 composite plans ranked against 16 evaluative criteria results in 3 composite plans detailed evaluation leads to 1 recommended plan

8 Orleans CWMP




Three Plans Evaluated in Detail

Plan 1 — Decentralized system with 4 treatment sites and 11 disposal sites across Town

Plan 2 — “Centralized” treatment and disposal at Tri-Town site

Plan 3 — “Centralized” treatment in So. Orleans with disposal on Brewster/Harwich golf courses

9 Orleans CWMP



Results of Summer 2008 Workshops

Most favored plan — Plan 2 by 70% of respondents

- ❖ \$25 million lower cost
- ❖ Most appropriate site/watershed

Most frequent comments:

- ❖ consider town-wide sewers
- ❖ regionalization is important
- ❖ reuse is desirable

10 Orleans CWMP




Plan Recommended by WMSC

“Centralized” treatment and disposal at site of Tri-Town septage facility

Plus.....

- ❖ use of Title 5 systems for half of Town
- ❖ cluster systems in most threatened sub-watersheds
- ❖ potential for future So. Orleans treatment facility with irrigation
- ❖ option for future effluent reuse
- ❖ strong non-structural program







11 Orleans CWMP




Two Types of Actions

1. Structural Elements (sewering)
 - Proven effectiveness
 - High cost
2. Non-Structural Elements (non-sewer)
 - Much lower cost
 - Less effective (not adequate alone)
 - Not fully proven or accepted by DEP

12 Orleans CWMP





- Environmental Evaluation**
- Factors considered:**
1. Surface water quality
 2. Groundwater quality
 3. Wetlands
 4. Floodplains
 5. Coastal resources
 6. Open space and recreation
 7. Generation of solid wastes
- 26 Orleans CWMP

- Environmental Evaluation**
8. Rare and endangered species
 9. Arch. and historic resources
 10. Traffic
 11. Air quality
 12. Noise
 13. Energy and greenhouse gases
 14. Erosion control
 15. Land use & community growth
- 27 Orleans CWMP

- Environmental Mitigations**
- Avoid summer sewer construction
 - Control dust and siltation at all sites
 - Use natural buffers and constructed berms at treatment facility site
 - Minimize box turtle habitat destruction
 - Provide high level of odor, noise control
 - Use high-efficiency equipment
 - Implement energy management plan
 - Document historic/archaeologic resources
- 28 Orleans CWMP

Long-term Schedule

<u>Task</u>	<u>Completion</u>
Final CWMP	late 2010
Preliminary design	2013
Final design—Phase 1	2013--2014
Bidding—Phase 1	late 2014
TM appropriation—Phase 1	spring 2015
Phase 1 construction	2015--2017
Start-up of Phase 1 facilities	mid 2017
Complete all 6 phases	2032

29 Orleans CWMP

Capital Costs—mid 2008 dollars


<u>Component</u>	<u>Cost, million</u>
Collection	102
Treatment	27
Disposal	8
Sludge/septage	3
Cluster systems	3
Land	5
Total	\$148

30 Orleans CWMP

Costs for Operation & Maintenance	
Component	Annual Cost
Labor	580,000
Energy	234,000
Sludge disposal	204,000
Maintenance & repair	192,000
Chemicals	50,000
Other	110,000
Total	\$1,370,000

31 Orleans CWMP


- ### Focus of CWMP Update
1. Box turtle habitat
 2. Cluster systems
 3. Regionalization
 4. Greenhouse gas emissions
 5. Tri-Town site capacity
 6. Independent technical review
- 32 Orleans CWMP



- ### Cluster Systems
1. Early nitrogen removal near "headwaters embayments"
 2. Remove at least 60% of TMDL
 3. Perhaps convert to Pump Stations in later phases
 4. Each system serves 25 to 40 homes (124 home in total, 60,000 gpd)
 5. Effluent quality: 5 to 8 mg/l N
- 34 Orleans CWMP

- ### Wastewater Regionalization Study
- Options for Orleans, Eastham and Brewster:
1. Each town acts alone
 2. Regional treatment facilities
 - > Orleans and Eastham
 - > Orleans and Brewster
 - > All three towns
 3. Orleans expands its sewer system to provide N removal for the region
- 35 Orleans CWMP

- ### Wastewater Regionalization Study
- Preliminary findings:
- > 6% to 9% savings in capital cost
 - > 18% to 25% savings in costs for operation and maintenance
 - > Cost allocation formulas evaluated to share savings
 - > Schedule will be dictated by Eastham and Brewster
- 36 Orleans CWMP




Independent Technical Review

Funding from Cape Cod Water Protection Collaborative
 Sept 2010 Report by CH2M--key conclusions:

- > **Public consultation:** comprehensive, transparent, well documented, effective
- > **Decentralized option:** may not be feasible due to site acquisition problems
- > **Cost savings measures:** should be aggressively pursued, esp. regional
- > **Recommended Plan:** sound, based on good science and engineering, and should be implemented expeditiously


37 Orleans CWMP



Outcome of MEPA Review

See Jan 28, 2011 Certificate of the EOEEA Secretary:
“The project adequately and properly complies with the Massachusetts Environmental Policy Act and its implementing regulations.”
 State, regional and local agency review comments very favorable


38 Orleans CWMP



Issues Raised at January 18, 2011 Hearing

- Alternative sewer systems
- Decentralized options
- Science behind MEP technical reports
- Trends in Pleasant Bay water quality
- Moving water among watersheds
- Impacts of groundwater mounding
- Impacts on Namskaket Marsh

39 Orleans CWMP



Alternative Sewer Systems

CWMP considered:

- > Traditional gravity sewers and force mains
- > Grinder pumps and low-pressure sewers
- > Vacuum sewers
- > STEP systems

Design process will focus on gravity sewers, supplemented by other systems as site conditions allow to effect lowest overall cost
 Treatment and disposal elements of CWMP are not changed by choice of collection system

40 Orleans CWMP



Decentralized Options

Town evaluated 3 plans in detail, one involving decentralized systems

- > significantly more expensive
- > not favored by public


Independent engineer

- > raised doubts about the feasibility of the decentralized option
- > strongly supported recommended plan

Barnstable County Wastewater Cost Report

- > independently supports Orleans' analysis

41 Orleans CWMP



Town Investigation of Estuarine “Science”

Validation and Design Committee
 Expert consultant—Woods Hole Group
 Important consultant finding:
“MEP reports...represent strong foundation for developing a course of action to develop and comply with site-specific TMDL requirements”
 MEP science is not the subject of the DRI review
 CWMP is based on the “science of record”

42 Orleans CWMP

Trends in Pleasant Bay Water Quality

Cadmus Group (Oct 2010) reviewed 10 years of Pleasant Bay Water quality data

Since 2nd inlet formation in 2007:

- > Most stations show no statistically significant change
- > Some open-water stations some show improvement
- > Headwaters embayments continue to decline
- > Bioactive N concentrations continue to exceed MEP target restoration values

DEP's stance—the 2007 breach may not provide a long-term solution, and towns should plan for less favorable conditions

43 Orleans CWMP

Major Watersheds

Map showing Major Watersheds with percentages:

- CAPE COD BAY: 15%, 20%, 31%
- NAUSSET: 21%, 27%, 77%
- ATLANTIC OCEAN: 2%, 3%, 4%
- PLEASANT BAY: 62% of Land Area, 50% of Population, 38% of Commercial Lots

44 Orleans CWMP

Regional Water Balance

Average recharge in million gallons per day

Watershed	Now	Change	Future
Pleasant Bay	31.38	-0.25	31.13
Atlantic Ocean	0.55	0	0.55
Nauset System	4.76	-0.19	4.57
Cape Cod Bay	<u>7.67</u>	<u>+0.44</u>	<u>8.11</u>
Town-wide	44.36	0	44.36

Wet-Year Increase = 10 million gallons per day

45 Orleans CWMP

Evaluation of Tri-Town Site Capacity

Surficial soil permeability
6.7 gpd/sf needed, 7.7 gpd/sf estimated

Mounding
4-ft minimum separation, 25 feet predicted

Local Impacts
No negative impacts expected

Fate of residual nitrogen
Namsk. and Little Namsk. below thresholds
No impact on Rock Harbor, Town Cove

46 Orleans CWMP

Hydrogeologic Investigations

USGS Cape-wide computer model

- Basis for MEP watershed boundaries
- Applied to Orleans project in 2006

Measurement of GW elevations and contaminant concentrations by USGS (1990s through 2004)

Large-scale loading test in 2007

Supplemental explorations in 2008

Fine-tuning of USGS model in 2008

47 Orleans CWMP

Application of USGS Model to Site







Model made more "fine-grained" in vicinity of site and down gradient






Local hydrology considered to a greater extent

Soil layers at depth varied to reflect best available information

Calibration to local data under both wet and dry conditions

48 Orleans CWMP





Nitrogen Loads to Namskaket System

Effluent Nitrogen Loads

	With Proposed Project		
	No Action	No Growth	With Growth
Effluent Flow, gpd	32,000	470,000	640,000
Concentration, mg/l	32	3	3
Effluent Load, lb/yr	3,100	4,300	5,800
Portion to System	100%	70%	67%
Load to System, lb/yr	3,100	3,000	3,900

60 Orleans CWMP

Relative Magnitude of Tri-Town Load

How much is 3,100 lb/yr of nitrogen?

- > All of the average Tri-Town effluent
- > Septic system discharge from 200 homes

Notes:

- > there are now 500 homes (equiv.) in the Namskaket system
 - 300 in Brewster
 - 200 in Orleans
- > expected growth—100 more homes

61 Orleans CWMP

Regional Groundwater Flow

62 Orleans CWMP

Flows to Namskaket

How much of effluent will eventually reach Namskaket system?

MEP	100%
CWMP	
> Full project—no growth	70%
> Full project—with growth	67%
USGS (Weiskel)	20% ??

63 Orleans CWMP

Namskaket System Nitrogen Loads

Nitrogen Loads in pounds per year

<u>Source</u>	<u>With Proposed Project</u>		
	<u>No Action</u>	<u>No Growth</u>	<u>With Growth</u>
Septic Systems (O+B)	7,900	7,900	9,600
Tri-Town Facility	3,100	0	0
New Wastewater Plant	0	3,000	3,900
Private Facilities	<u>200</u>	<u>200</u>	<u>200</u>
Total	11,200	11,100	13,700

System Assimilative Capacity = 37,000 lb/yr

64 Orleans CWMP

MEP Technical Report—Namskaket System

Massachusetts Estuaries Project

Linked Watershed-Embayment Model to Determine Critical Nitrogen Loading Thresholds for the Namskaket Marsh Estuarine System, Orleans, MA

Draft 2007
Final Dec. 2008

UNIVERSITY OF MASSACHUSETTS DARTMOUTH School of Marine Science and Technology
MASSACHUSETTS DEPARTMENT OF Environmental Protection

FINAL REPORT - December 2008




65 Orleans CWMP

Namskaket System Assimilative Capacity

Nitrogen Loads as Percentage of Assimilative Capacity

<u>Source</u>	<u>With Proposed Project</u>		
	<u>No Action</u>	<u>No Growth</u>	<u>With Growth</u>
Septic Systems (O+B)	21.4%	21.4%	26.0%
Tri-Town Facility	8.5%	0.0%	0.0%
New Wastewater Plant	0.0%	8.1%	10.6%
Private Facilities	<u>0.4%</u>	<u>0.4%</u>	<u>0.6%</u>
Total	30.3%	29.9%	37.1%

66 Orleans CWMP



Nitrogen Assimilation in Namskaket System

The assimilative capacity of Namskaket Marsh is largely within the tidal portion of Namskaket Creek which forms the boundary between Orleans and Brewster

Of the nitrogen assimilation that now occurs:

- > 32% applies to Brewster septic systems
- > 24% applies to Orleans septic systems

70 Orleans CWMP

Groundwater Discharge Permit Program

Regulated pursuant to 314 CMR 5.00
 Requires hydrogeological evaluation (mostly completed in CWMP)
 DEP considers down-gradient sensitive receptors and sets limits to protect them
 Review of design plans
 Permitting process involves opportunity for public comment
 Permit will specify monitoring program

71 Orleans CWMP

